

**DMR Copy of Record**

<b>Permit</b>			
<b>Permit #:</b>	<b>AR0035645</b>	<b>Permittee:</b>	GLENWOOD, CITY OF
<b>Major:</b>	No	<b>Permittee Address:</b>	210 NORTH SECOND ST GLENWOOD, AR 71943
<b>Permitted Feature:</b>	001 External Outfall	<b>Discharge:</b>	<b>001-A</b> 001-MONTHLY-TRTD MUNICIPAL WW
<b>Facility:</b>	GLENWOOD, CITY OF		
<b>Facility Location:</b>	BAKER ROAD - 1.0 MI E OF CADDO RIVER BRIDGE ON HWY GLENWOOD, AR 71943		

<b>Report Dates &amp; Status</b>			
<b>Monitoring Period:</b>	<b>From 12/01/19 to 12/31/19</b>	<b>DMR Due Date:</b>	<b>01/25/20</b>
<b>Status:</b>	<b>NetDMR Validated</b>		

**Considerations for Form Completion**  
 Report flow as monthly average & daily maximum in MGD (million gallons/day). (S) Use Overflows (74062) to report total number of SSOs/Month. Use Overflow volume (74063) to report total volume of SSOs in gallons/month. Report "0" (zero), if no overflows during the entire month. See Part II. 5. (SSO). 55-00034

<b>Principal Executive Officer</b>			
<b>First Name:</b>	Billy	<b>Title:</b>	Mayor
<b>Last Name:</b>	Smith	<b>Telephone:</b>	870-356-3316

**No Data Indicator (NODI)**  
 Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type			
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3	Units	
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	0	--	Sample	=	10.1				=	10.1				19 - mg/L	0	02/30 - Twice Per Month	GR - GRAB	
					Permit Req.	>=	5.0 INST MIN								19 - mg/L	02/30 - Twice Per Month		GR - GRAB		
					Value NODI															
00400	pH	1 - Effluent Gross	0	--	Sample	=	6.8				=	6.8		=	7.0	12 - SU	0	02/30 - Twice Per Month	GR - GRAB	
					Permit Req.	>=	6.0 MINIMUM					<=	9.0 MAXIMUM	12 - SU	02/30 - Twice Per Month	GR - GRAB				
					Value NODI															
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	24.8		26 - lb/d		=	6.3		=	6.6	19 - mg/L	0	02/30 - Twice Per Month	GR - GRAB	
					Permit Req.	<=	51.3 MO AVG		26 - lb/d		<=	15.0 MO AVG	<=	22.5 7 DA AVG	19 - mg/L	02/30 - Twice Per Month		GR - GRAB		
					Value NODI															
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	0	--	Sample	=	0.3		26 - lb/d		=	0.08		=	0.08	19 - mg/L	0	02/30 - Twice Per Month	GR - GRAB	
					Permit Req.	<=	17.1 MO AVG		26 - lb/d		<=	5.0 MO AVG	<=	7.5 7 DA AVG	19 - mg/L	02/30 - Twice Per Month		GR - GRAB		
					Value NODI															
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.32629	=	0.649	03 - MGD							0	05/07 - Weekdays	IN - INSTAN	
					Permit Req.		Req Mon MO AVG		Req Mon DAILY MX	03 - MGD						05/07 - Weekdays		IN - INSTAN		
					Value NODI															
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample								<	0.02	19 - mg/L	0	02/30 - Twice Per Month	GR - GRAB		
					Permit Req.								<=	0.033 INST MAX	19 - mg/L		02/30 - Twice Per Month	GR - GRAB		
					Value NODI															
51040	E. coli	1 - Effluent Gross	0	--	Sample								<	1.0	13 - #/100mL	0	02/30 - Twice Per Month	GR - GRAB		
					Permit Req.								<=	126.0 30DA GEO	<=		126.0 7 DA GEO	13 - #/100mL	02/30 - Twice Per Month	GR - GRAB
					Value NODI															
74062	Overflows	S - See Comments	0	--	Sample	=	0.0			93 - occur/mo								999 - See Comments	999 - See Comments	
					Permit Req.		Req Mon MO TOTAL		93 - occur/mo							999 - See Comments		999 - See Comments		
					Value NODI															
74063	Overflow volume [SS0 volume, CSO volume]	S - See Comments	0	--	Sample	=	0.0			57 - gal								999 - See Comments	999 - See Comments	
					Permit Req.		Req Mon MO TOTAL		57 - gal							999 - See Comments		999 - See Comments		
					Value NODI															
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	0	--	Sample	<	7.73			26 - lb/d		<	2.0	=	2.0	19 - mg/L	0	02/30 - Twice Per Month	GR - GRAB	
					Permit Req.	<=	34.2 MO AVG		26 - lb/d		<=	10.0 MO AVG	<=	15.0 7 DA AVG	19 - mg/L	02/30 - Twice Per Month		GR - GRAB		
					Value NODI															

**Submission Note**  
 If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

**Edit Check Errors**  
 No errors.

**Comments**  
 Environmental Services Company, Inc. 13715 West Markham Little Rock, Arkansas 72211 (501) 221-2565

**Attachments**  
 No attachments.

**Report Last Saved By**  
**GLENWOOD, CITY OF**

User: BT@GWOOD  
 Name: Billy Smith  
 E-Mail: bt@glenwoodar.com

Date/Time: 2020-01-09 13:05 (Time Zone: -06:00)

**Report Last Signed By**

User: BT@GWOOD

Name: Billy Smith

E-Mail: bt@glenwoodar.com

Date/Time: 2020-01-09 13:08 (Time Zone: -06:00)