

**DMR Copy of Record**

**Permit**

<b>Permit #:</b>	<b>AR0035645</b>	<b>Permittee:</b>	GLENWOOD, CITY OF	<b>Facility:</b>	GLENWOOD, CITY OF
<b>Major:</b>	No	<b>Permittee Address:</b>	210 NORTH SECOND ST SEC-11 TWP-5S RNG-24W GLENWOOD, AR 71943	<b>Facility Location:</b>	BAKER ROAD - 1.0 MI E OF CADDO RIVER BRIDGE ON HWY GLENWOOD, AR 71943
<b>Permitted Feature:</b>	001 External Outfall	<b>Discharge:</b>	<b>001-A</b> 001-MONTHLY-TRTD MUNICIPAL WW		

**Report Dates & Status**

<b>Monitoring Period:</b>	<b>From 10/01/20 to 10/31/20</b>	<b>DMR Due Date:</b>	<b>11/25/20</b>	<b>Status:</b>	<b>NetDMR Validated</b>
---------------------------	----------------------------------	----------------------	-----------------	----------------	-------------------------

**Considerations for Form Completion**

Report flow as monthly average & daily maximum in MGD (million gallons/day). (S) Use Overflows (74062) to report total number of SSOs/Month. Use Overflow volume (74063) to report total volume of SSOs in gallons/month. Report "0" (zero), if no overflows during the entire month. See Part II. 5. (SSO). 55-00034

**Principal Executive Officer**

<b>First Name:</b>	Billy	<b>Title:</b>	Mayor	<b>Telephone:</b>	870-365-3613
<b>Last Name:</b>	Smith				

**No Data Indicator (NODI)**

Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type		
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3	Units
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	0	--	Sample					=	7.9					19 - mg/L	02/30 - Twice Per Month	GR - GRAB	
					Permit Req.					>=	5.0 INST MIN					19 - mg/L			
					Value NODI														
00400	pH	1 - Effluent Gross	0	--	Sample					=	6.8			=	7.0	12 - SU	02/30 - Twice Per Month	GR - GRAB	
					Permit Req.					>=	6.0 MINIMUM			<=	9.0 MAXIMUM	12 - SU			
					Value NODI														
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	<	6.93					<	3.3	=	3.8	19 - mg/L	02/30 - Twice Per Month	GR - GRAB	
					Permit Req.	<=	51.3 MO AVG				<=	15.0 MO AVG	<=	22.5 7 DA AVG	19 - mg/L				
					Value NODI														
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	0	--	Sample	=	0.06					=	0.03	=	0.04	19 - mg/L	02/30 - Twice Per Month	GR - GRAB	
					Permit Req.	<=	17.1 MO AVG				<=	5.0 MO AVG	<=	7.5 7 DA AVG	19 - mg/L				
					Value NODI														
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.26	=	0.598	03 - MGD							05/07 - Weekdays	IN - INSTAN	
					Permit Req.		Req Mon MO AVG		Req Mon DAILY MX	03 - MGD							05/07 - Weekdays	IN - INSTAN	
					Value NODI														
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample								=	0.0	19 - mg/L	02/30 - Twice Per Month	GR - GRAB		
					Permit Req.							<=	0.033 INST MAX	19 - mg/L					
					Value NODI														
51040	E. coli	1 - Effluent Gross	0	--	Sample							=	17.0	=	17.0	13 - #/100mL	02/30 - Twice Per Month	GR - GRAB	
					Permit Req.						<=	126.0 30DA GEO	<=	126.0 7 DA GEO	13 - #/100mL				
					Value NODI														
74062	Overflows	S - See Comments	0	--	Sample	=	0.0										999 - See Comments	999 - See Comments	
					Permit Req.		Req Mon MO TOTAL											999 - See Comments	999 - See Comments
					Value NODI														
74063	Overflow volume [SS0 volume, CSO volume]	S - See Comments	0	--	Sample	=	0.0										999 - See Comments	999 - See Comments	
					Permit Req.		Req Mon MO TOTAL											999 - See Comments	999 - See Comments
					Value NODI														
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	0	--	Sample	<	5.63					<	2.8	=	3.7	19 - mg/L	02/30 - Twice Per Month	GR - GRAB	
					Permit Req.	<=	34.2 MO AVG				<=	10.0 MO AVG	<=	15.0 7 DA AVG	19 - mg/L				
					Value NODI														

**Submission Note**

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

**Edit Check Errors**

No errors.

**Comments**

Environmental Services Company, Inc. 13715 West Markham Street Little Rock, AR 72211 501-221-2565

**Attachments**

No attachments.

**Report Last Saved By**

**GLENWOOD, CITY OF**

User: BT@GWOOD  
Name: Billy Smith  
E-Mail: bt@glenwoodar.com  
Date/Time: 2020-11-20 08:28 (Time Zone: -06:00)

**Report Last Signed By**

User: BT@GWOOD  
Name: Billy Smith  
E-Mail: bt@glenwoodar.com  
Date/Time: 2020-11-20 08:34 (Time Zone: -06:00)