

DMR Copy of Record

Permit			
Permit #:	AR0035645	Permittee:	GLENWOOD, CITY OF
Major:	No	Permittee Address:	210 NORTH SECOND ST GLENWOOD, AR 71943
Permitted Feature:	001 External Outfall	Discharge:	001-A 001-MONTHLY-TRTD MUNICIPAL WW
Facility:	GLENWOOD, CITY OF		
Facility Location:	BAKER ROAD - 1.0 MI E OF CADDO RIVER BRIDGE ON HWY GLENWOOD, AR 71943		

Report Dates & Status			
Monitoring Period:	From 01/01/20 to 01/31/20	DMR Due Date:	02/25/20
Status:	NetDMR Validated		

Considerations for Form Completion
 Report flow as monthly average & daily maximum in MGD (million gallons/day). (S) Use Overflows (74062) to report total number of SSOs/Month. Use Overflow volume (74063) to report total volume of SSOs in gallons/month. Report "0" (zero), if no overflows during the entire month. See Part II. 5. (SSO). 55-00034

Principal Executive Officer			
First Name:	Title:	Telephone:	
Last Name:			

No Data Indicator (NODI)
 Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration						# of Ex.	Frequency of Analysis	Sample Type		
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3				Units	
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	0	--	Sample					=	9.63					19 - mg/L	02/30 - Twice Per Month	GR - GRAB		
					Permit Req.					>=	5.0 INST MIN				19 - mg/L					
					Value NODI															
00400	pH	1 - Effluent Gross	0	--	Sample					=	7.0			=	7.0	12 - SU	02/30 - Twice Per Month	GR - GRAB		
					Permit Req.					>=	6.0 MINIMUM			<=	9.0 MAXIMUM	12 - SU				
					Value NODI															
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	<	6.9						<	2.5	<	2.5	19 - mg/L	02/30 - Twice Per Month	GR - GRAB	
					Permit Req.	<=	51.3 MO AVG					<=	15.0 MO AVG	<=	22.5 7 DA AVG	19 - mg/L				
					Value NODI															
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	0	--	Sample	=	0.05					=	0.02	=	0.02	19 - mg/L	02/30 - Twice Per Month	GR - GRAB		
					Permit Req.	<=	17.1 MO AVG					<=	5.0 MO AVG	<=	7.5 7 DA AVG	19 - mg/L				
					Value NODI															
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.385548	=	0.615	03 - MGD							05/07 - Weekdays	IN - INSTAN		
					Permit Req.		Req Mon MO AVG		Req Mon DAILY MX	03 - MGD										
					Value NODI															
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample									<	0.02	19 - mg/L	02/30 - Twice Per Month	GR - GRAB		
					Permit Req.									<=	0.033 INST MAX	19 - mg/L				
					Value NODI															
51040	E. coli	1 - Effluent Gross	0	--	Sample									<	3.2	=	5.0	13 - #/100mL	02/30 - Twice Per Month	GR - GRAB
					Permit Req.									<=	126.0 30DA GEO	<=	126.0 7 DA GEO	13 - #/100mL		
					Value NODI															
74062	Overflows	S - See Comments	0	--	Sample	=	0.0									93 - occur/mo	999 - See Comments	999 - See Comments		
					Permit Req.		Req Mon MO TOTAL									93 - occur/mo				
					Value NODI															
74063	Overflow volume [SS0 volume, CSO volume]	S - See Comments	0	--	Sample	=	0.0									57 - gal	999 - See Comments	999 - See Comments		
					Permit Req.		Req Mon MO TOTAL									57 - gal				
					Value NODI															
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	0	--	Sample	<	6.02						<	2.3	=	2.5	19 - mg/L	02/30 - Twice Per Month	GR - GRAB	
					Permit Req.	<=	34.2 MO AVG					<=	10.0 MO AVG	<=	15.0 7 DA AVG	19 - mg/L				
					Value NODI															

Submission Note
 If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors
 No errors.

Comments
 Environmental Services Company, Inc. 13715 West Markham Little Rock, Arkansas 72211 (501) 221-2565

Attachments
 No attachments.

Report Last Saved By
GLENWOOD, CITY OF

User: BT@GWOOD
 Name: Billy Smith
 E-Mail: bt@glenwoodar.com

Date/Time: 2020-02-18 08:30 (Time Zone: -06:00)

Report Last Signed By

User: BT@GWOOD

Name: Billy Smith

E-Mail: bt@glenwoodar.com

Date/Time: 2020-02-18 08:30 (Time Zone: -06:00)