

DMR Copy of Record

Permit

Permit #:	AR0035645	Permittee:	GLENWOOD, CITY OF	Facility:	GLENWOOD, CITY OF
Major:	No	Permittee Address:	210 NORTH SECOND ST GLENWOOD, AR 71943	Facility Location:	BAKER ROAD - 1.0 MI E OF CADDO RIVER BRIDGE ON HWY GLENWOOD, AR 71943
Permitted Feature:	001 External Outfall	Discharge:	001-A 001-MONTHLY-TRTD MUNICIPAL WW		

Report Dates & Status

Monitoring Period:	From 03/01/20 to 03/31/20	DMR Due Date:	04/25/20	Status:	NetDMR Validated
---------------------------	----------------------------------	----------------------	-----------------	----------------	-------------------------

Considerations for Form Completion

Report flow as monthly average & daily maximum in MGD (million gallons/day). (S) Use Overflows (74062) to report total number of SSOs/Month. Use Overflow volume (74063) to report total volume of SSOs in gallons/month. Report "0" (zero), if no overflows during the entire month. See Part II. 5. (SSO). 55-00034

Principal Executive Officer

First Name:		Title:		Telephone:	
Last Name:					

No Data Indicator (NODI)

Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration						# of Ex.	Frequency of Analysis	Sample Type
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3	Value 3			
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	0	--	Sample					=	9.06					19 - mg/L	02/30 - Twice Per Month	GR - GRAB
					Permit Req.					>=	5.0 INST MIN				19 - mg/L			
					Value NODI													
00400	pH	1 - Effluent Gross	0	--	Sample					=	6.7			=	8.8	12 - SU	02/30 - Twice Per Month	GR - GRAB
					Permit Req.					>=	6.0 MINIMUM		<=	9.0 MAXIMUM	12 - SU			
					Value NODI													
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	12.74					=	4.65	=	4.9	19 - mg/L	02/30 - Twice Per Month	GR - GRAB
					Permit Req.	<=	51.3 MO AVG				<=	15.0 MO AVG	<=	22.5 7 DA AVG	19 - mg/L			
					Value NODI													
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	0	--	Sample	=	0.1					=	0.04	=	0.04	19 - mg/L	02/30 - Twice Per Month	GR - GRAB
					Permit Req.	<=	17.1 MO AVG				<=	5.0 MO AVG	<=	7.5 7 DA AVG	19 - mg/L			
					Value NODI													
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.42771	=	0.642	03 - MGD							05/07 - Weekdays	IN - INSTAN
					Permit Req.		Req Mon MO AVG		Req Mon DAILY MX	03 - MGD								
					Value NODI													
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample								=	0.02	19 - mg/L	02/30 - Twice Per Month	GR - GRAB	
					Permit Req.							<=	0.033 INST MAX	19 - mg/L				
					Value NODI													
51040	E. coli	1 - Effluent Gross	0	--	Sample							<	9.2	=	16.8	13 - #/100mL	02/30 - Twice Per Month	GR - GRAB
					Permit Req.						<=	126.0 30DA GEO	<=	126.0 7 DA GEO	13 - #/100mL			
					Value NODI													
74062	Overflows	S - See Comments	0	--	Sample	=	0.0									93 - occur/mo	999 - See Comments	999 - See Comments
					Permit Req.		Req Mon MO TOTAL								93 - occur/mo			
					Value NODI													
74063	Overflow volume [SS0 volume, CSO volume]	S - See Comments	0	--	Sample	=	0.0									57 - gal	999 - See Comments	999 - See Comments
					Permit Req.		Req Mon MO TOTAL								57 - gal			
					Value NODI													
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	0	--	Sample	=	9.84					=	3.6	=	4.1	19 - mg/L	02/30 - Twice Per Month	GR - GRAB
					Permit Req.	<=	34.2 MO AVG				<=	10.0 MO AVG	<=	15.0 7 DA AVG	19 - mg/L			
					Value NODI													

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Environmental Services Company, Inc. 13715 West Markham Little Rock, Arkansas 72211 (501) 221-2565

Attachments

No attachments.

Report Last Saved By

GLENWOOD, CITY OF

User: BT@GWOOD
 Name: Billy Smith
 E-Mail: bt@glenwoodar.com

Date/Time: 2020-04-20 10:21 (Time Zone: -05:00)

Report Last Signed By

User: BT@GWOOD

Name: Billy Smith

E-Mail: bt@glenwoodar.com

Date/Time: 2020-04-20 10:21 (Time Zone: -05:00)