

DMR Copy of Record

Permit

Permit #:	AR0035645	Permittee:	GLENWOOD, CITY OF	Facility:	GLENWOOD, CITY OF
Major:	No	Permittee Address:	210 NORTH SECOND ST SEC-11 TWP-5S RNG-24W GLENWOOD, AR 71943	Facility Location:	BAKER ROAD - 1.0 MI E OF CADDO RIVER BRIDGE ON HWY GLENWOOD, AR 71943
Permitted Feature:	001 External Outfall	Discharge:	001-A 001-MONTHLY-TRTD MUNICIPAL WW		

Report Dates & Status

Monitoring Period:	From 05/01/20 to 05/31/20	DMR Due Date:	06/25/20	Status:	NetDMR Validated
---------------------------	----------------------------------	----------------------	-----------------	----------------	-------------------------

Considerations for Form Completion

Report flow as monthly average & daily maximum in MGD (million gallons/day). (S) Use Overflows (74062) to report total number of SSOs/Month. Use Overflow volume (74063) to report total volume of SSOs in gallons/month. Report "0" (zero), if no overflows during the entire month. See Part II. 5. (SSO). 55-00034

Principal Executive Officer

First Name:	Billy	Title:	Mayor	Telephone:	870-356-3613
Last Name:	Smith				

No Data Indicator (NODI)

Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type		
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3	Units
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	0	--	Sample					=	8.47					19 - mg/L	02/30 - Twice Per Month	GR - GRAB	
					Permit Req.					>=	5.0 INST MIN					19 - mg/L			
					Value NODI														
00400	pH	1 - Effluent Gross	0	--	Sample					=	6.6			=	7.1	12 - SU	02/30 - Twice Per Month	GR - GRAB	
					Permit Req.					>=	6.0 MINIMUM			<=	9.0 MAXIMUM	12 - SU			
					Value NODI														
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	<	6.71						<	2.5	<	2.5	19 - mg/L	02/30 - Twice Per Month	GR - GRAB
					Permit Req.	<=	51.3 MO AVG					<=	15.0 MO AVG	<=	22.5 7 DA AVG	19 - mg/L			
					Value NODI														
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	0	--	Sample	=	5.5						=	2.36	=	4.59	19 - mg/L	02/30 - Twice Per Month	GR - GRAB
					Permit Req.	<=	17.1 MO AVG					<=	5.0 MO AVG	<=	7.5 7 DA AVG	19 - mg/L			
					Value NODI														
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.409258	=	0.733	03 - MGD							05/07 - Weekdays	IN - INSTAN	
					Permit Req.		Req Mon MO AVG										05/07 - Weekdays	IN - INSTAN	
					Value NODI														
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample									=	0.02	19 - mg/L	02/30 - Twice Per Month	GR - GRAB	
					Permit Req.									<=	0.033 INST MAX	19 - mg/L			
					Value NODI														
51040	E. coli	1 - Effluent Gross	0	--	Sample								=	46.0	=	46.0	13 - #/100mL	02/30 - Twice Per Month	GR - GRAB
					Permit Req.								<=	126.0 30DA GEO	<=	126.0 7 DA GEO	13 - #/100mL		
					Value NODI														
74062	Overflows	S - See Comments	0	--	Sample	=	0.0										999 - See Comments	999 - See Comments	
					Permit Req.		Req Mon MO TOTAL										999 - See Comments	999 - See Comments	
					Value NODI														
74063	Overflow volume [SS0 volume, CS0 volume]	S - See Comments	0	--	Sample	=	0.0										999 - See Comments	999 - See Comments	
					Permit Req.		Req Mon MO TOTAL										999 - See Comments	999 - See Comments	
					Value NODI														
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	0	--	Sample	=	12.01						=	4.9	=	7.6	19 - mg/L	02/30 - Twice Per Month	GR - GRAB
					Permit Req.	<=	34.2 MO AVG					<=	10.0 MO AVG	<=	15.0 7 DA AVG	19 - mg/L			
					Value NODI														

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Environmental Services Company, Inc. 13715 West Markham Street Little Rock, AR 72211 501-221-2565

Attachments

No attachments.

Report Last Saved By

GLENWOOD, CITY OF

User: BT@GWOOD
Name: Billy Smith
E-Mail: bt@glenwoodar.com
Date/Time: 2020-06-18 14:34 (Time Zone: -05:00)

Report Last Signed By

User: BT@GWOOD
Name: Billy Smith
E-Mail: bt@glenwoodar.com
Date/Time: 2020-06-18 14:34 (Time Zone: -05:00)