

DMR Copy of Record

Permit

| | | | | | |
|---------------------------|-------------------------|---------------------------|--|---------------------------|--|
| Permit #: | AR0035645 | Permittee: | GLENWOOD, CITY OF | Facility: | GLENWOOD, CITY OF |
| Major: | No | Permittee Address: | 210 NORTH SECOND ST SEC-11 TWP-5S RNG-24W GLENWOOD, AR 71943 | Facility Location: | BAKER ROAD - 1.0 MI E OF CADDO RIVER BRIDGE ON HWY GLENWOOD, AR 71943 |
| Permitted Feature: | 001 External Outfall | Discharge: | 001-A 001-MONTHLY-TRTD MUNICIPAL WW | | |

Report Dates & Status

| | | | | | |
|---------------------------|----------------------------------|----------------------|-----------------|----------------|-------------------------|
| Monitoring Period: | From 06/01/20 to 06/30/20 | DMR Due Date: | 07/25/20 | Status: | NetDMR Validated |
|---------------------------|----------------------------------|----------------------|-----------------|----------------|-------------------------|

Considerations for Form Completion

Report flow as monthly average & daily maximum in MGD (million gallons/day). (S) Use Overflows (74062) to report total number of SSOs/Month. Use Overflow volume (74063) to report total volume of SSOs in gallons/month. Report "0" (zero), if no overflows during the entire month. See Part II. 5. (SSO). 55-00034

Principal Executive Officer

| | | | | | |
|--------------------|-------|---------------|-------|-------------------|--------------|
| First Name: | Billy | Title: | Mayor | Telephone: | 870-365-3613 |
| Last Name: | Smith | | | | |

No Data Indicator (NODI)

Form NODI: --

| Code | Parameter Name | Monitoring Location | Season # | Param. NODI | Quantity or Loading | | | | | Quality or Concentration | | | | | # of Ex. | Frequency of Analysis | Sample Type | |
|-------|--|---------------------|----------|-------------|---------------------|---------|------------------|---------|------------------|--------------------------|--------------|-------------|----------------|----------------|----------------|--|--|--|
| | | | | | Qualifier 1 | Value 1 | Qualifier 2 | Value 2 | Units | Qualifier 1 | Value 1 | Qualifier 2 | Value 2 | Qualifier 3 | | | | Value 3 |
| 00300 | Oxygen, dissolved [DO] | 1 - Effluent Gross | 0 | -- | Sample | | | | | = | 8.31 | | | | | 19 - mg/L | 03/30 - Three Per Month 02/30 - Twice Per Month | GR - GRAB GR - GRAB |
| | | | | | Permit Req. | | | | | >= | 5.0 INST MIN | | | | | 19 - mg/L | | |
| | | | | | Value NODI | | | | | | | | | | | | | |
| 00400 | pH | 1 - Effluent Gross | 0 | -- | Sample | | | | | = | 6.7 | | | = | 7.0 | 12 - SU | 03/30 - Three Per Month 02/30 - Twice Per Month | GR - GRAB GR - GRAB |
| | | | | | Permit Req. | | | | | >= | 6.0 MINIMUM | | | <= | 9.0 MAXIMUM | 12 - SU | | |
| | | | | | Value NODI | | | | | | | | | | | | | |
| 00530 | Solids, total suspended | 1 - Effluent Gross | 0 | -- | Sample | = | 17.0 | | | | | = | 5.6 | = | 6.8 | 19 - mg/L | 03/30 - Three Per Month 02/30 - Twice Per Month | GR - GRAB GR - GRAB |
| | | | | | Permit Req. | <= | 51.3 MO AVG | | | | | <= | 15.0 MO AVG | <= | 22.5 7 DA AVG | 19 - mg/L | | |
| | | | | | Value NODI | | | | | | | | | | | | | |
| 00610 | Nitrogen, ammonia total [as N] | 1 - Effluent Gross | 0 | -- | Sample | < | 0.33 | | | | | < | 0.1 | = | 0.23 | 19 - mg/L | 03/30 - Three Per Month 02/30 - Twice Per Month | GR - GRAB GR - GRAB |
| | | | | | Permit Req. | <= | 17.1 MO AVG | | | | | <= | 5.0 MO AVG | <= | 7.5 7 DA AVG | 19 - mg/L | | |
| | | | | | Value NODI | | | | | | | | | | | | | |
| 50050 | Flow, in conduit or thru treatment plant | 1 - Effluent Gross | 0 | -- | Sample | = | 0.332853 | = | 0.621 | 03 - MGD | | | | | | | 01/01 - Daily 05/07 - Weekdays | IN - INSTAN IN - INSTAN |
| | | | | | Permit Req. | | Req Mon MO AVG | | Req Mon DAILY MX | 03 - MGD | | | | | | | | |
| | | | | | Value NODI | | | | | | | | | | | | | |
| 50060 | Chlorine, total residual | 1 - Effluent Gross | 0 | -- | Sample | | | | | | | | < | 0.02 | 19 - mg/L | 03/30 - Three Per Month 02/30 - Twice Per Month | GR - GRAB GR - GRAB | |
| | | | | | Permit Req. | | | | | | | | <= | 0.033 INST MAX | 19 - mg/L | | | |
| | | | | | Value NODI | | | | | | | | | | | | | |
| 51040 | E. coli | 1 - Effluent Gross | 0 | -- | Sample | | | | | | | < | 21.1 | = | 109.2 | 13 - #/100mL | 03/30 - Three Per Month 02/30 - Twice Per Month | GR - GRAB GR - GRAB |
| | | | | | Permit Req. | | | | | | | <= | 126.0 30DA GEO | <= | 126.0 7 DA GEO | 13 - #/100mL | | |
| | | | | | Value NODI | | | | | | | | | | | | | |
| 74062 | Overflows | S - See Comments | 0 | -- | Sample | = | 0.0 | | | | | | | | | | 999 - See Comments 999 - See Comments | 999 - See Comments 999 - See Comments |
| | | | | | Permit Req. | | Req Mon MO TOTAL | | | | | | | | | | | |
| | | | | | Value NODI | | | | | | | | | | | | | |
| 74063 | Overflow volume [SS0 volume, CS0 volume] | S - See Comments | 0 | -- | Sample | = | 0.0 | | | | | | | | | | 999 - See Comments 999 - See Comments | 999 - See Comments 999 - See Comments |
| | | | | | Permit Req. | | Req Mon MO TOTAL | | | | | | | | | | | |
| | | | | | Value NODI | | | | | | | | | | | | | |
| 80082 | BOD, carbonaceous [5 day, 20 C] | 1 - Effluent Gross | 0 | -- | Sample | < | 9.63 | | | | | < | 3.2 | = | 4.4 | 19 - mg/L | 03/30 - Three Per Month 02/30 - Twice Per Month | GR - GRAB GR - GRAB |
| | | | | | Permit Req. | <= | 34.2 MO AVG | | | | | <= | 10.0 MO AVG | <= | 15.0 7 DA AVG | 19 - mg/L | | |
| | | | | | Value NODI | | | | | | | | | | | | | |

Submission Note

If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

Edit Check Errors

No errors.

Comments

Environmental Services Company, Inc. 13715 West Markham Street Little Rock, AR 72211 501-221-2565

Attachments

No attachments.

Report Last Saved By

GLENWOOD, CITY OF

User: BT@GWOOD
Name: Billy Smith
E-Mail: bt@glenwoodar.com
Date/Time: 2020-07-15 13:07 (Time Zone: -05:00)

Report Last Signed By

User: BT@GWOOD
Name: Billy Smith
E-Mail: bt@glenwoodar.com
Date/Time: 2020-07-15 13:52 (Time Zone: -05:00)