

DMR Copy of Record

<b>Permit</b>		<b>Permittee:</b> GLENWOOD, CITY OF		<b>Facility:</b> GLENWOOD, CITY OF	
<b>Permit #:</b>	AR0035645	<b>Permittee Address:</b>	210 NORTH SECOND ST SEC-11 TWP-5S RNG-24W GLENWOOD, AR 71943	<b>Facility Location:</b>	BAKER ROAD - 1.0 MI E OF CADDO RIVER BRIDGE ON HWY GLENWOOD, AR 71943
<b>Major:</b>	No	<b>Discharge:</b>	001-A 001-MONTHLY-TRTD MUNICIPAL WW		
<b>Permitted Feature:</b>	001 External Outfall				

<b>Report Dates &amp; Status</b>					
<b>Monitoring Period:</b>	From 08/01/20 to 08/31/20	<b>DMR Due Date:</b>	09/25/20	<b>Status:</b>	NetDMR Validated

**Considerations for Form Completion**  
 Report flow as monthly average & daily maximum in MGD (million gallons/day). (S) Use Overflows (74062) to report total number of SSOs/Month. Use Overflow volume (74063) to report total volume of SSOs in gallons/month. Report "0" (zero), if no overflows during the entire month. See Part II. 5. (SSO). 55-00034

<b>Principal Executive Officer</b>					
<b>First Name:</b>	Billy	<b>Title:</b>	Mayor	<b>Telephone:</b>	870-365-3613
<b>Last Name:</b>	Smith				

**No Data Indicator (NODI)**  
 Form NODI: --

Code	Parameter Name	Monitoring Location	Season #	Param. NODI	Quantity or Loading					Quality or Concentration					# of Ex.	Frequency of Analysis	Sample Type					
					Qualifier 1	Value 1	Qualifier 2	Value 2	Units	Qualifier 1	Value 1	Qualifier 2	Value 2	Qualifier 3				Value 3	Units			
00300	Oxygen, dissolved [DO]	1 - Effluent Gross	0	--	Sample	=	7.63										19 - mg/L	02/30 - Twice Per Month	GR - GRAB			
					Permit Req.	>=	5.0 INST MIN												19 - mg/L	02/30 - Twice Per Month	GR - GRAB	
					Value NODI																	
00400	pH	1 - Effluent Gross	0	--	Sample	=	6.4										12 - SU	14/30 - 14 Per Month	GR - GRAB			
					Permit Req.	>=	6.0 MINIMUM												12 - SU	02/30 - Twice Per Month	GR - GRAB	
					Value NODI																	
00530	Solids, total suspended	1 - Effluent Gross	0	--	Sample	=	9.38			26 - lb/d							19 - mg/L	02/30 - Twice Per Month	GR - GRAB			
					Permit Req.	<=	51.3 MO AVG			26 - lb/d									19 - mg/L	02/30 - Twice Per Month	GR - GRAB	
					Value NODI																	
00610	Nitrogen, ammonia total [as N]	1 - Effluent Gross	0	--	Sample	=	0.31			26 - lb/d							19 - mg/L	02/30 - Twice Per Month	GR - GRAB			
					Permit Req.	<=	17.1 MO AVG			26 - lb/d									19 - mg/L	02/30 - Twice Per Month	GR - GRAB	
					Value NODI																	
50050	Flow, in conduit or thru treatment plant	1 - Effluent Gross	0	--	Sample	=	0.344323		0.621	03 - MGD								01/01 - Daily	IN - INSTAN			
					Permit Req.		Req Mon MO AVG		Req Mon DAILY MX	03 - MGD										05/07 - Weekdays	IN - INSTAN	
					Value NODI																	
50060	Chlorine, total residual	1 - Effluent Gross	0	--	Sample												19 - mg/L	02/30 - Twice Per Month	GR - GRAB			
					Permit Req.															19 - mg/L	02/30 - Twice Per Month	GR - GRAB
					Value NODI																	
X 51040	E. coli	1 - Effluent Gross	0	--	Sample												13 - #/100mL	02/30 - Twice Per Month	GR - GRAB			
					Permit Req.															13 - #/100mL	02/30 - Twice Per Month	GR - GRAB
					Value NODI																	
74062	Overflows	S - See Comments	0	--	Sample	=	0.0			93 - occur/mo								999 - See Comments	999 - See Comments			
					Permit Req.		Req Mon MO TOTAL		93 - occur/mo											999 - See Comments	999 - See Comments	
					Value NODI																	
74063	Overflow volume [SS0 volume, CSO volume]	S - See Comments	0	--	Sample	=	0.0			57 - gal								999 - See Comments	999 - See Comments			
					Permit Req.		Req Mon MO TOTAL		57 - gal											999 - See Comments	999 - See Comments	
					Value NODI																	
80082	BOD, carbonaceous [5 day, 20 C]	1 - Effluent Gross	0	--	Sample	<	14.28			26 - lb/d							19 - mg/L	02/30 - Twice Per Month	GR - GRAB			
					Permit Req.	<=	34.2 MO AVG		26 - lb/d										19 - mg/L	02/30 - Twice Per Month	GR - GRAB	
					Value NODI																	

**Submission Note**  
 If a parameter row does not contain any values for the Sample nor Effluent Trading, then none of the following fields will be submitted for that row: Units, Number of Excursions, Frequency of Analysis, and Sample Type.

<b>Edit Check Errors</b>						
Parameter Code	Parameter Name	Monitoring Location	Field	Type	Description	Acknowledge
51040	E. coli	1 - Effluent Gross	Quality or Concentration Sample Value 3	Soft	The provided sample value is outside the permit limit. Please verify that the value you have provided is correct. (Error Code: 1)	Yes

**Comments**

Environmental Services Company, Inc. 13715 West Markham Street Little Rock, AR 72211 501-221-2565

**Attachments**

Name	Type	Size
NONCOMPLIANCEREPORT2020AUGUST.docx	docx	14193.0

**Report Last Saved By**

**GLENWOOD, CITY OF**

User: BT@GWOOD  
Name: Billy Smith  
E-Mail: bt@glenwoodar.com  
Date/Time: 2020-09-18 08:57 (Time Zone: -05:00)

**Report Last Signed By**

User: BT@GWOOD  
Name: Billy Smith  
E-Mail: bt@glenwoodar.com  
Date/Time: 2020-09-18 08:57 (Time Zone: -05:00)